

CROSS CONNECTION CONTROL PLAN

WHITE CITY MOBILE ESTATES
3265 ANTELOPE ROAD
WHITE CITY, OR 97503

P.W.S. ID# 4100334

1/16/97

(This plan is being submitted to the Oregon Health Division/Drinking Water Section)

I. Purpose

- A. To protect the potable water supply of White City Mobile Estates from the possibility of contamination or pollution by isolating, within its tenants internal distribution system, such contaminants or pollutants which could backflow or backsiphon into the water system.
- B. To promote the elimination of, or control of, existing cross connections, actual or potential, between the potable water system and sources of non-potable water or other hazardous substances.
- C. To provide for the maintenance of a continuing program of cross connection control which will effectively prevent the contamination or pollution of all potable water systems by cross connection.

II. Authority

The Federal Safe Drinking Water Act of 1974, and the statutes of the State of Oregon, Administrative Rules Chapters #333-61-070, #333-61-071, and #333-61-072 state that the water supplier has the primary responsibility for the preventing of water from unapproved sources, or any other substances, from entering the potable water system.

III. Responsibility

White City Mobile Estates shall be responsible for the protection of the Mobile Home Parks potable water system from contamination or pollution due to the backflow or backsiphonage of contaminants or pollutants through the water service connection. If, in the judgment of White City Mobile Estates, an approved backflow device is required at the water connection to any tenants site, White City Mobile Estates, or his delegated agent, shall give notice in writing to said tenant to install an approved backflow prevention device at each service connection to his site. The tenant shall, within ninety (90) days, install such approved device, or devices, at his own expense, and failure or refusal, or inability on the part of the tenant to install said device or devices within ninety (90) days, shall constitute a ground for discontinuing water service to the site until such device or devices have been properly installed.

IV. Administration

- A. White City Mobile Estates will operate a cross connection control program, to include the keeping of necessary records, which fulfills the requirements of the Division's Cross Connection Regulations.
- B. The tenant shall allow his site to be inspected for possible cross connections and shall follow the provisions of White City Mobile Estates program and the Division's regulations if a cross connection is identified.
- C. If White City Mobile Estates requires that the water supply be protected by containment, the tenant shall be responsible for water quality beyond the outlet end of the containment device and should utilize a backflow device for that purpose. He may utilize public health officials, or other qualified personnel such as a licensed plumber, to assist in the survey of the mobile home unit and to assist in the selection and installation of property fixture outlet devices.

V. Requirements

1. The tenant shall be responsible for the elimination or isolation of all cross connections on his site.
2. The tenant, after having been informed by a letter from White City Mobile Estates, shall at his expense, install, maintain, and test, or have tested, any and all backflow preventers at his site annually.

