

4100406
**SUNSHINE VILLAGE
WATER ASSOCIATION**

Fisher L. Forrest, Chairman
274 Upper Applegate Rd.
Jacksonville, OR 97530-9739

Phone: 541-899-1338
Fax: 541-899-2554
E-mail:
fisherforrest@sprintmail.com

August 26, 1999

To: All subscribers, Sunshine Village Water Association

**FOLLOWING ARE THE CURRENT REGULATIONS ENACTED BY
THE BOARD OF TRUSTEES RELATING TO UNDERGROUND
SPRINKLER SYSTEMS:**

Plans for underground sprinkling systems must be submitted to the Board of Trustees for approval prior to installation of the system. Systems will be limited to 10 gallons per minute and must have properly installed and maintained vacuum breakers or other approved back flow prevention devices.

If lots are fenced, gates must be provided to allow access to valve boxes, water main, and blow down valve stations.

These are the regulations enacted pursuant to the inauguration of the Association in 1972.

FISHER L. FORREST, Chairman

