

SEAL ROCK WATER DISTRICT

Resolution No. 10-11-90

A RESOLUTION PROVIDING FOR THE CONTROL OF CROSS-CONNECTIONS WITH THE DISTRICT WATER SYSTEM.

THE SEAL ROCK WATER DISTRICT, SEAL ROCK, OREGON, RESOLVES AS FOLLOWS:

Section 1. Definitions.

(a) "Air Gap Separation" means the physical vertical separation between the free-flowing discharge end of a potable water supply pipeline and the open or non-pressure receiving vessel.

(b) "Approval" or "Approved" means approved in writing.

(c) "Auxiliary Water Supply" means any supply of water used to augment the supply obtained from the district water system which serves the premises in question.

(d) "AWWA" means the American Water Works Association.

(e) "Backflow" means the flow in the direction opposite to the normal flow.

(f) "Backflow Prevention Device" or "Backflow Prevention Device Assembly" means a backflow prevention device such as a pressure vacuum breaker, a double check valve, or a reduced pressure principle device, and the attached shut-off valves on the inlet and outlet ends of the device assembled as a complete unit.

(g) "Check Valve" means a valve which allows flow in only one direction.

(h) "District Water System" shall mean the potable water system of the Seal Rock Water District.

(i) "Cross Connection" means any link or channel between the piping which carries drinking water and the piping or fixtures which carry other water or other substances.

(j) "Division" means the Health Division of the Oregon Department of Human Resources.

(k) "Double Check Valve Assembly" means an assembly of two independently acting check valves with shut-off valves on each side

C
L
I
E
N
T

C
O
P
Y

of the check valves and test cocks for checking the watertightness of each check valve.

(l) "Owner" means any person owing a beneficial interest with a right of possession in property served by the municipal water system, any occupant of any premises served by the district water system, and any customer or water uses of the district water system.

(m) "Person" includes any individual, corporation, association, firm, partnership, municipal, state or federal agency, or joint stock company and includes any receiver, special master, trustee, assignee or other similar representative thereof.

(n) "Potable Water" means safe drinking water.

(o) "District Water Superintendent" means the District Water Superintendent for the Seal Rock Water District or the District Water Superintendent Designee.

(p) "Reduced Pressure Principle Backflow Prevention Device (R.P. Device)" means a device for preventing backflow which has two check valves, a differential relief valve located between the two check valves, two shut-off valves, one on the upstream side and the other on the downstream side of the check valves, and four test cocks for checking the watertightness of the check valves and the operation of the relief valve.

(q) "Safe Drinking Water" means water which has sufficiently low concentrations of microbiological, inorganic chemical, organic chemical, radiological or physical substances so that individuals drinking such water at normal levels of consumption, will not be exposed to disease organisms or other substances which may produce harmful physiological effects.

(r) "Service Connection" means the piping connection by means of which water is conveyed from a distribution main of a public water system to a customer's premises. The portion of the service connection which conveys water from the distribution main to the customer's property line, or to the service meter where provided, is owned by and under the jurisdiction of the water supplier.

(s) "Water System" means a system for the provision of piped water for human consumption.

Section 2. Cross-Connection Control Requirements.

(a) Whenever a water user or the owner of the premises obtaining water from the district water system treats the water in any way or adds any chemical or substance to the water, such person

C
L
I
E
N
T
C
O
P
Y

shall immediately notify the District Water Superintendent.

(b) Backflow prevention device assemblies for protecting the district water system shall be installed on the owner's side of the service connection to premises where an approved air gap does not exist and:

(1) There is an auxiliary water supply which is connected to the potable water piping.

(2) There is an auxiliary water supply which could be connected to the potable water piping, unless all of the following requirements are met:

(A) The auxiliary water supply is not, in fact, connected to the potable water piping.

(B) The auxiliary water supply is conspicuously posted with a sign identifying it as a non-potable water supply and prohibiting it from being connected to the district water supply or any potable water supply system on the premises. The location and contents of the sign shall be determined by the District Water Superintendent.

(C) The owner permits inspections, at such time as the District Water Superintendent may determine, to determine whether the auxiliary water supply has been connected to the potable water supply system or the district water supply system.

(D) If any inspection reveals that the auxiliary water system has been connected to the district water system or any potable water system on the premises, the District Water Superintendent may, upon thirty (30) days' written notice to the owner, require installation of a backflow prevention device assembly at the service connection.

(3) There is intricate plumbing which makes it impractical to ascertain whether or not cross-connections exist.

(4) There is back siphonage potential.

(5) Cross-connections or potential cross-connections exist.

(c) The type of backflow prevention device required under paragraph (b) of this section, shall be commensurate with the degree of hazard which exists and shall be installed at the owner's expense:

(1) An approved air gap of at least twice the inside diameter, but not less than one inch, of the incoming supply line

measured vertically above the top rim of the vessel, or an approved reduced pressure (RP) device assembly shall be installed where the substance which could backflow is hazardous to health, such as but not limited to sewage treatment plants, sewage pumping stations, chemical manufacturing plants, plating plants, hospitals, mortuaries, car washes, medical clinics;

(2) An approved double check valve assembly shall be installed where the substance which could backflow is objectionable, but does not pose an unreasonable risk to health;

(3) An approved pressure vacuum breaker or an atmospheric breaker shall be installed where the substance which could backflow is objectionable, but does not pose an unreasonable risk to health and where there is no possibility of back pressure in the downstream piping. A shut-off valve may be installed on the line downstream of a pressure vacuum breaker, but shall not be installed downstream of an atmospheric vacuum breaker.

(d) Except as set forth in paragraph (f) of this section, all backflow prevention device assemblies required under this section shall be of a type or model approved by the Division.

(e) All backflow prevention device assemblies shall be installed in accordance with Chapter 2 and Chapter 4, Recommended Installation Practice, Accepted Procedure and Practice in Cross-Connection Control Manual, November, 1985, 4th ed. Published by the Cross-Connection Control Committee, Pacific Northwest Section, AWWA.

Need to refer to OAR 333-601-071

(f) Backflow prevention device assemblies installed before the effective date of this ordinance which were approved at the time they were installed, but are not on the current list of approved device assemblies maintained by the Division, shall be permitted to remain in service provided they are properly maintained, are commensurate with the degree of hazard, are tested at least annually, and perform satisfactorily. When devices of this type are moved, or require more than minimum maintenance, they shall be replaced by device assemblies which are on the Division list of approved device assemblies.

(g) The water user or the owner of the premises where one or more reduced pressure device assemblies, double check valve assemblies or pressure vacuum breakers have been installed shall have the device or devices tested, at the owner's or user's expense, at least once per year. Devices shall be tested immediately after installation and after they are moved. Reports on the test shall be prepared by the tester and copies of the reports shall be provided to the water user or the owner of the premises, to the Seal Rock Water District, ~~and to the Division~~ within fifteen

C
L
I
E
N
T

C
O
P
Y

(15) days of the date the test is conducted. Tests shall be performed by certified testers in conformance with the procedures established by the Foundation for Cross-Connection Control and Hydraulic Research, Manual of Cross-Connection Control, 7th ed., June 1985, University of Southern California. OAR 333-61-070(10)

Need to refer to OHD test reqmts

(h) If any backflow prevention devices are found not to be functioning properly, the District Water Superintendent shall give notice to the water user or owner of the premises. The notice shall require that the owner or water user repair the backflow prevention device within thirty (30) days of the mailing of the notice, unless the District Water Superintendent determines that the potential backflow could be hazardous to health, in which case the notice period may be shortened to such time as the District Water Superintendent may determine.

Section 3. Notices. Any notice required or permitted under this ordinance shall be deemed given upon mailing to the address of the premises served or to the billing address of the water user listed with the district water department.

Section 4. Shut-Offs. The District Water Superintendent may shut off the water service to any premises when:

(a) A violation of this ordinance continues after the expiration of any notice period provided under this ordinance.

(b) Immediately, upon determination that an emergency exists or that a substantial hazard exists due to the potential for backflow of hazardous substances.

(c) Immediately upon the refusal of any water user or owner of premises to permit inspection, or if the District Water Superintendent is unable to contact the water user or owner to arrange for an inspection.

Failure to test or install a backflow device. OAR 333-61-070(1)(a)(A)

Section 5. Inspections. All water users and owners of premises served by the Seal Rock Water system shall permit inspections by the District Water Superintendent, at such time as the District Water Superintendent may designate, for purposes of determining whether the water user or owner is in compliance with this ordinance.

Section 6. Fees. Fees for inspections by the District Water Superintendent, and for signs posted in accordance with Section 2(b)(2)(B), shall be set by resolution. Fees for turn-ons and shut-offs shall be in accordance with the fee resolution of _____.

Section 7. Penalties. Violations of this ordinance shall be

punishable by a fine not to exceed \$ 75.00.

Section 8. Separate Violations. Each day that a violation of this ordinance continues shall constitute a separate violation.

Section 9. Constitutionality and Saving Clause. If any clause, sentence, paragraph, section, article or portion of this ordinance shall, for any reason, be adjudged invalid or unenforceable by a court of competent jurisdiction, the remainder of the ordinance shall remain in full force and effect.

PASSED BY unanimous vote of all commissioners present this 11th day of October, 1990.

Ray Kowalski
Ray Kowalski, Chairman
Executed this 12 day of October, 1990

ATTEST:

Claire M. Edmiston
CLAIRE M. EDMISTON, Secretary
Executed this 13th day of December, 1990

6~

C
L
I
E
N
T

C
O
P
Y