

SRH Water Corp.

South Redmond Heights 41-01230

Cross Connection Control Requirements and Ordinance

No Customer or agent of the customer shall introduce or permit the introduction of pollution or contamination of any kind into the SRH Water Corporation supply system. Whenever a cross connection or any other condition is found which presents the possibility of contamination or pollution, the water supply to such premises and/or other premises from which cross connection is made shall be discontinued immediately until the cross connection is eliminated or the condition remedied. SRH Water Corporation will control cross connections, and other pollution to the public water system by periodic inspections of premises where it is thought that cross connection, or pollution could or does exist.

The elimination of cross connections shall be in accordance with any manuals of standard practice pertaining to cross connection control, approved by the administrator of the Corporation, and any requirements set forth by the **OREGON ADMINISTRATIVE RULES CHAPTER 333-61-070**, and the **ACCEPTED PROCEDURE AND PRACTICE IN CROSS CONNECTION CONTROL MANUAL/FOURTH EDITION**. Or any revision there of. Or any requirements set forth by the "**U. S. ENVIRONMENTAL PROTECTION AGENCY**" as authorized by the "**SAFE DRINKING WATER ACT**" 93-523 and subsequent applicable legislation.

The Water Corporation shall require a Backflow prevention device of pattern, design and size which is approved by the Oregon State Health Division, and which is on the current list of approved devices furnished by the Health Division. The Backflow device shall be adequate to prevent contamination, and commensurate with the degree of hazard, if the Administrator determines that a complete physical separation from the Water Corporation system is not practicable or necessary, or that adequate inspection for cross connection cannot readily be made, or that such Backflow prevention device is necessary because of existing or possible blackflow resulting from special conditions, use or equipment.

The Water Corporation shall also regulate the location, installation and testing of such device. Any corrective measure, disconnection or change on private property shall be a the sole expense of the person in control of such property.

Page 2

The cost of any Change required in the Water Corporation system outside the property or between the meter and the supply line or distribution system and any charges for cut-off or disconnection shall be added to the charges for water against the premises necessitating the expenditures.

Any person operating any mobile apparatus which uses the Water Corporation's water system or water from any premises within the Water Corporation must provide for Backflow prevention.

TESTING OF BACKFLOW PREVENTION DEVICES.

Any backflow devices required by the Water Corporation to be installed on a customer's premises for the protection of the public water supply shall be tested immediately upon installation and on each anniversary thereafter. Such tests shall be performed only by a certified tester. (results of the Tests shall be reported immediately to SRH Water Corporation). If a test report is not received within thirty days of the date on which the test certification is due, the Water Corporation may elect to order such test and add the cost of such test, and repairs to the device if necessary, to the customer's water bill.