

01353

HAPPY HOLLOW WATER CO

RECEIVED
FEB 13 2012
FIELD SERVICES
DRINKING WATER PROGRAM

REVISED FEB 6, 2012

Cross Connection Control Program

HAPPY HOLLOW WATER COMPANY(HHWC) CROSS CONNECTION CONTROL POLICY REQUIRES THAT ANY HOME CONNECTED TO HHWC WATER SYSTEM THAT HAS THE POTENTIAL TO BE CONTAMINATED BY A BACKFLOW SYSTEM OF NON-POTABLE/CONTAMINATED WATER INTO THE POTABLE WATER SUPPLY BE PROTECTED BY A BACK FLOW PREVENTION DEVICE.

THE HOME OWNER WILL BE RESPONSIBLE FOR INSTALLING A REDUCED PRESSURE BACK FLOW ASSEMBLY OR DOUBLE CHECK BACK FLOW PREVENTION DEVICE EITHER AT THE POINT OF USE OR AT THE CONNECTION OF THE HHWC DISTRIBUTION AND THE DWELLING SERVICE LINE. PRESSURE VACUUM BREAKERS AND ATMOSPHERIC VACUUM ARE NOT ALLOWED ON THE HHWC SYSTEM.

ANY HOME INSTALLING AN APPROVED BACK FLOW DEVICE MUST HAVE IT TESTED ANNUALLY AND PROVIDE A COPY OF THE TEST RESULTS TO THE OPERATOR OF HHWC.

THANK YOU,

**JEAN EDWARDS
OWNER/OPERATOR**