

WESTERN HEIGHTS WATER CO

RECEIVED

JAN 14 2008

41-01358

Drinking Water Program  
Dept. of Human Services

CONNECTION TO THE WESTERN HEIGHTS WATER ASSOCIATION WATER SYSTEM BY LOT OWNERS.

EACH CONNECTION SHALL BE MADE THROUGH A WATER METER PURCHASED FROM THE WESTERN HEIGHTS WATER ASSOCIATION.

THE INSTALLATION OF THE METER SHALL BE BY AN LICENSED PLUMBER OR OTHER PERSON APPROVED BY THE WESTERN HEIGHTS WATER ASSOCIATION MAINTENANCE PERSONNEL.

THE WATER METER SHALL NOT BE REMOVED OR REPAIRED BY THE LOT OWNER OR OTHER UNAUTHORIZED PERSONS. REPAIR AND MAINTENANCE WILL BE PERFORMED BY WESTERN HEIGHTS WATER ASSOCIATION MAINTENANCE PERSONNEL OR THEIR APPROVED AGENT.

LOT OWNERS SHALL NOT MAKE ANY CONNECTION OR ALTERATION TO THE DOMESTIC WATER SYSTEM UNDER THEIR CONTROL THAT WOULD ALLOW A FOREIGN SUBSTANCE TO BE INTRODUCED INTO THE WESTERN HEIGHTS WATER SYSTEM.

UNDERGROUND IRRIGATION SYSTEMS THAT ARE HARD PLUMBED TO THE WESTERN HEIGHTS WATER SYSTEM OR ATTACHED BY A HOSE, MUST NOT INCORPORATE ANY TYPE OF A DEVICE THAT WOULD INTRODUCE ANY FOREIGN SUBSTANCE INTO THE IRRIGATION SYSTEM. THIS WOULD INCLUDE BUT NOT LIMITED TO FERTILIZER, HERBICIDE, INSECTICIDE, ETC.

IRRIGATION SYSTEMS THAT ARE HARD PLUMED TO THE WESTERN HEIGHTS WATER SYSTEM MUST HAVE A STATE OF OREGON APPROVED BACK FLOW DEVICE INSTALLED IN THE APPROVED MANNER AND BE TESTED ANNUALLY.

HOT TUBS THAT ARE HARD PLUMBED TO THE WESTERN HEIGHTS WATER SYSTEM MUST HAVE A STATE OF OREGON APPROVED BACK FLOW DEVICE INSTALLED IN THE APPROVED MANNER AND BE TESTED ANNUALLY.

HOT TUBS THAT ARE FILLED MANUALLY WITH A HOSE DOT NOT REQUIRE A BACK FLOW DEVICE.

FAILURE TO COMPLY WITH THE LISTED REQUIREMENT WILL BE REASON FOR DISCONTINUING SERVICE TO THE PREMISES.