

Enabling Authority

Water System Name: Elk City Water District

Water System PWS ID # 41- 01549 Revised Date: March 7, 2022

Purpose

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with Oregon Administrative Rules (OARs) 333-061-0070 through 333-061-0074.

Requirements

Actual or potential cross connections are prohibited. If a potential exists for a cross connection the water system must be protected by an appropriate backflow prevention device or assembly.

Any high hazards, as specified in the OARs will be given the highest priority, and protected with an approved air gap or reduced pressure backflow assembly.

Enforcement

The water system has the right to refuse or terminate water service to any customer who does not:

- Install a backflow device or assembly, when an actual or potential cross connection exists.
- Test the assembly at least annually and complete necessary repairs

The water system reserves the right to require a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

The water system will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

Additional

A list of all high hazard connections and how they are protected from a cross connection is attached to this enabling authority.

This enabling authority is approved and adopted and will remain in effect as of this date until such time as revised or eliminated.

Printed Name: Gene Crawford

Title: President

Signature: 

Date: 3/7/2022

Printed Name: Shannon Crawford

Title: Secretary

Signature: 

Date: 3/7/2022

Elk City Water District Back Flow Devices List as of February 15, 2022

Street #	Street	Suffix	Last Name	Location	Serial #	Make Model Size
2195	SAGE ROAD FIRE		SPACE LLC	FS VAULT-NORTHWEST END OF LOT	1029301	DCDA AME 3000SE 8.00
625	CHARLES WAY FIRE		N A R PROPERTIES LLC	FIRE SERVICE VAULT	145449	DCDA AME 3000SS 6.00
325-333	325-333 EHRMAN FIRE		B A PROPERTIES	FIRE SERVICE VAULT NE OF 325	1590600	DCDA AME 3000SS 8.00
349-355	349-355 EHRMAN FIRE		M & J FLARLI FOUNDATION	FS vault SW corner of 349	1504810606	DCDA AME 3000SS 8.00
578	MASON WAY FIRE		GTS INTERIOR SUPPLY	FIRE VAULT	G3755	DCDA DER BD-CV .50
578	MASON WAY FIRE		GTS INTERIOR SUPPLY	FIRE VAULT EAST SIDE OF BLDG	G71792	DCDA DERINGER DERINGER30 6.00
960	MASON WAY FIRE		FERGUSON WATER WORKS	FIRE SERVICE VAULT IN FRONT OF 950 MASON	1271	DCDA WAT 774DCDA 6.00
2221	JOSEPH ST FIRE		SPACE LLC	PUMP HOUSE	V08660	DCDA WIL 350ADA 8.00
325-333	325-333 EHRMAN FIRE		B A PROPERTIES	FIRE SERVICE VAULT NE OF 325	55674	DCV AME 2000B .75
349-355	349-355 EHRMAN FIRE		M & J FLARLI FOUNDATION	FIRE SERVICE VAULT SW CORNER OF 349	50872	DCV AME 2000B .75
910	MASON	WAY	WESTERN BEVERAGE LLC	SW CORNER OF BUILDING	436	DCV AME 2000B 1.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	BEHIND METER SOUTH OF ENTRANCE	155735	DCV AME 2000SS 10.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	Fire pump room	177746	DCV AME 2000SS 6.00
1208	BEALL	LN	WOODY FAMILY PROP LLC	NORTH SIDE OF BLDG	Z0587	DCV CON 40105A2 1.00
2194	SAGE	RD	HUTTIG BUILDING PRODUCTS	SE of house	he83172	DCV FEB 850 1.00
2221	JOSEPH	ST	SPACE LLC	PUMP HOUSE	10300	DCV WAT 007 2.50
960	MASON WAY FIRE		FERGUSON WATER WORKS	FIRE SERVICE VAULT IN FRONT OF 950 MASON	46595	DCV WAT 007M1QT .75
625	CHARLES WAY FIRE		N A R PROPERTIES LLC	FIRE SERVICE VAULT	66271	DCV WAT 007M1QT .75
2195	SAGE ROAD FIRE		SPACE LLC	FS VAULT -NW END OF LOT	59387	DCV WAT 007M1QT .75
3496	EDELLA	AVE	CHAMBERS	NW OF HOUSE	272146	DCV WAT 007M1QT 1.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	SW CORNER OF PLYWOOD PLANT	70637	DCV WAT 007M1QT 2.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	SE CORNER PLY PLANT BEHIND GLUE TANKS	71971	DCV WAT 007M1QT 2.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	PLY CURTAIN COATER GLUE AREA	70464	DCV WAT 007M1QT 2.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	SPRAY LINE GLUE AREA	70055	DCV WAT 007M1QT 2.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	UNDER PUTTY LINE SOUTH	205362	DCV WAT 007M2QT .75
1208	BEALL	LN	WOODY FAMILY PROP LLC	12' north of meter	a09110	DCV WAT 007M2QT 1.25
2221	JOSEPH	ST	SPACE LLC	PUMP HOUSE	A04262	DCV WAT 007M2QT 1.50
159	EHRMAN WAY FIRE /CIG		SPACE LLC	FS VAULT - NE END OF LOT - BYPASS	106599	DCV WAT 709 .75
159	EHRMAN WAY FIRE /CIG		SPACE LLC	FS VAULT - NE END OF LOT	101949	DCV WAT 709 6.00
910	MASON WAY FIRE		WESTERN BEVERAGE LLC	FS LINE VAULT S END OF PARKING LOT	103066	DCV WAT 709 8.00
910	MASON WAY FIRE		WESTERN BEVERAGE LLC	FS LINE VAULT - DDC BYPASS LINE	111407	DCV WAT 709QT .75

Street #	Street	Suffix	Last Name	Location	Serial #	Make Model Size
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	under loft north of glue tanks	29741	DCV WAT LF007M1QT 1.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	Under north spray line	73831	DCV WAT LF007M2QT 1.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	2nd level of glue tanks loft	7636	DCV WAT LF007M2QT 1.50
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	2nd level of glue tanks loft	36073	DCV WAT LF007M3QT .75
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	Fire Pump Room	42137	DCV WIL 350 4.00
2221	JOSEPH ST FIRE		SPACE LLC	PUMP HOUSE	2323952	DCV WIL 950XL .75
1208	BEALL	LN	WOODY FAMILY PROP LLC	CONTROL BOX WEST SIDE OF BLDG	297334	DCV WIL 950XL 1.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	Behind meter on Erman Street	7872	DVC WAT LF007M1QT 2.00
HIGH HAZARD DEVICES						
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	POWER HOUSE PUMP ROOM	TA733	RP CON 40208T2 2.00
3285	PACIFIC	HWY	BOISE CASCADE WP LLC	PAINT AND OILER STATION	361149	RP WAT 009M2QT 1.00
2293	SAGE	RD	CHERRY LANE INVESTMENTS LLC	SW CORNER OF EHRMAN & SAGE BY PHONE POLE	A16223	RP WAT 009M2QT 1.25
910	BEALL	LN	MCDOWELL	Corner of Beall and Bursell at meter	57335	RP WAT LF009M3QT .75
836	MASON WAY FIRE		CLASSIC TROLLEY	NON-TESTABLE SINGLE CHECK	36	SCV
836	MASON WAY FIRE		CLASSIC TROLLEY	NON-TESTABLE SINGLE CHECK	4x	SCV
2175	JOSEPH ST FIRE		SUBURBAN PROPANE	NON-TESTABLE SINGLE CHECK	3X	SCV
2194	SAGE ROAD FIRE		HUTTING BUILDING PRODUCTS	NON-TESTABLE SINGLE CHECK	2x	SCV