

**Enabling Ordinance  
For Small Water System**

**Water System Name: Cypress Grove RV Park**

**Water System PWS ID #: 41-94910**

**Date of Approval of this ordinance: March 12, 2013**

**The purpose of this ordinance is to protect the health of the people served by Cypress Grove RV Park water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, we will comply with the following Oregon Administrative Rules (OAR) 333-061-0070 thru 333-061-0074. This includes installation, maintenance and annual testing of backflow prevention devices and assemblies and reporting backflow data to the Oregon Health Authority every year.**

**Actual or potential cross connections are prohibited. If a potential exists for a cross connection and this is necessary, the water system must be protected by an appropriate backflow prevention device or assembly.**

**Water service may be refused or terminated to any premises where an unprotected cross connection may allow contamination or pollutants to backflow into the public drinking water system**