

**OHA / DWP**

Oregon Health Authority

**Water Quality Parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

Day	pH	Alk	Phos	Sili	Y/N
1	7.28				Y
2	7.30				Y
3	7.25				Y
4	7.35				Y
5	7.31				Y
6	7.32				Y
7	7.33				Y
8	7.24				Y
9	7.34				Y
10	7.26				Y
11	7.31				Y
12	7.35				Y
13	7.31				Y
14	7.32				Y
15	7.21				Y
16	7.25				Y
17	7.22				Y
18	7.33				Y
19	7.27				Y
20	7.29				Y
21	7.28				Y
22	7.23				Y
23	7.29				Y
24	7.22				Y
25	7.30				Y
26	7.27				Y
27	7.27				Y
28	7.35				Y
29	7.30				Y
30	7.33				Y
1	0.00				-

<< Have minimums been met for this day?

**ENTRY POINT**  
**EP-C**  
**PWS ID: 4 | 1 | 0 | 0 | 5 | 0 | 5**

---

**SYSTEM NAME:** City of Manzanita

---

**SAMPLE PERIOD:** April-24  
MONTH / YEAR

**Number of excursions\* during this month:** 0

**(Over 9 excursions in 6 months is a violation.)**  
*Entry Point and Distribution excursions are cumulative)*

*\* An "excursion" is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameters set for this PWS:**

pH

**Print Name:** Daniel L. Weitzel

**Signature:** *Daniel L. Weitzel*

**Cert. #:** WD2- #7191 / WT2 - # 08183

**Date:** Tuesday, May 7, 2024

**Phone:** (503) 368-5347

(No = N = Excursion) Total N's **0**

**Send to DHS-DWP within 10 days after end of sampling period to:**  
**DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350**  
**Phone (971) 673-0405 Website: www.ohd.hr.state.or.us/dwp**