



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N | << Have minimums been met for this day? |
|-----|-----|-----|------|-------|-----|-----------------------------------------|
| 1 | 7.5 | | | | Y | |
| 2 | 7.5 | | | | Y | |
| 3 | 7.4 | | | | Y | |
| 4 | 7.6 | | | | Y | |
| 5 | 7.6 | | | | Y | |
| 6 | 7.8 | | | | Y | |
| 7 | 7.5 | | | | Y | |
| 8 | 7.6 | | | | Y | |
| 9 | 7.5 | | | | Y | |
| 10 | 7.5 | | | | Y | |
| 11 | 7.8 | | | | Y | |
| 12 | 7.8 | | | | Y | |
| 13 | 7.4 | | | | Y | |
| 14 | 7.5 | | | | Y | |
| 15 | 7.8 | | | | Y | |
| 16 | 7.5 | | | | Y | |
| 17 | 7.4 | | | | Y | |
| 18 | 7.5 | | | | Y | |
| 19 | 7.7 | | | | Y | |
| 20 | 7.7 | | | | Y | |
| 21 | 7.6 | | | | Y | |
| 22 | 7.6 | | | | Y | |
| 23 | 7.7 | | | | Y | |
| 24 | 7.7 | | | | Y | |
| 25 | 7.6 | | | | Y | |
| 26 | 7.4 | | | | Y | |
| 27 | 7.6 | | | | Y | |
| 28 | 7.5 | | | | Y | |
| 29 | 7.5 | | | | Y | |
| 30 | 7.7 | | | | Y | |

County: Tillamook Agency: REGION 1

ENTRY POINT

A

PWS ID 4100708

Rockaway Beach Water Dist.

Sample Period: Apr-24
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative), An 'excursion' is anyday in which water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Print Name: Luke Shepard

Signature: 

Date: 1-May-24

(No = N = Excursions)

Total N's 0

Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 732-4381 Website: www.ohd.hr.state.or.us/dwp