

Day	pH	Alk	Phos	Other	Y/N
1	7.8	61.6			Yes
2	7.7	61.6			
3	7.5	54.7			
4	7.7	54.7			
5	7.8	54.7			
6	7.8	61.6			
7	8.1	68.5			
8	7.5	61.6			
9	7.8	54.8			
10	7.7	54.8			
11	7.7	54.8			
12	7.3	41			
13	7.3	61			
14	7.5	54.8			
15	7.5	54.8			
16	7.7	82			
17	8	85			
18	8.4	120			
19	8.4	100			
20	8	68.5			
21	8	68.5			
22	8	90			
23	8.2	100			
24	8.3	100			
25	8.2	96			
26	8.3	90			
27	8.4	61.5			
28	8.4	98			
29	8	120			
30	8.2	100			
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: April / 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Larry Whitwood

Signature: [Signature]

Date: 5-6-2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0