

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name: Bella Casa Mobile Home Park **PWS ID#** 41 - 01005

Month/Year: June 2023 **Entry Point:** Kitchen Sink in Rec Rm **Required Minimum Residual:** 0.60 mg/L

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L15434)	0.78	
2	10:00:00 AM	WELL (L15434)	0.82	
3	10:00:00 AM	WELL (L15434)	0.68	
4	10:00:00 AM	WELL (L15434)	0.73	
5	6:00:00 AM	WELL (L15434)	0.89	
6	2:00:00 PM	WELL (L15434)	0.95	
7	10:00:00 AM	WELL (L15434)	0.85	
8	6:00:00 AM	WELL (L15434)	0.80	
9	6:00:00 PM	WELL (L15434)	0.95	
10	6:00:00 PM	WELL (L15434)	0.71	
11	6:00:00 PM	WELL (L15434)	0.78	
12	6:00:00 PM	WELL (L15434)	0.68	
13	10:00:00 AM	WELL (L15434)	0.97	
14	10:00:00 AM	WELL (L15434)	0.87	
15	6:00:00 AM	WELL (L15434)	0.76	
16	2:00:00 PM	WELL (L15434)	1.01	
17	2:00:00 PM	WELL (L15434)	0.79	
18	6:00:00 AM	WELL (L15434)	0.69	
19	6:00:00 AM	WELL (L15434)	0.93	
20	6:00:00 PM	WELL (L15434)	0.70	
21	10:00:00 AM	WELL (L15434)	1.11	
22	10:00:00 AM	WELL (L15434)	1.09	
23	2:00:00 PM	WELL (L15434)	0.88	
24	6:00:00 AM	WELL (L15434)	0.74	
25	6:00:00 AM	WELL (L15434)	0.78	
26	6:00:00 AM	WELL (L15434)	0.70	
27	10:00:00 AM	WELL (L15434)	0.64	
28	2:00:00 PM	WELL (L15434)	0.62	
29	2:00:00 PM	WELL (L15434)	0.63	
30	6:00:00 PM	WELL (L15434)	0.88	

Was the chlorine residual ever less than the required minimum residual of **.60 mg/L** Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to .60 mg/L?</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	---	---

<p>Printed Name: Dan Reitz</p> <p>Signature: </p> <p>Date: 7/3/2023</p>	<p>Title: Vice President</p> <p>Oregon Water Services, Inc.</p> <p>Phone#: (541) 342-1718</p>	<p>Operator Certification #: D:6528, T:6528</p> <p>OR</p> <p>Small Ground Water System</p>
---	---	---