

OHA - Drinking Water Services - Surface Water Quality Data Form

County: CLATSOP

Slow Sand Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year: Sep-21

System Name: City of Cannon Beach ID#410016 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.07				0.07
2			0.09				0.09
3			0.12				0.12
4			0.07				0.07
5			0.07				0.07
6			0.08				0.08
7			0.08				0.08
8			0.08				0.08
9			0.08				0.08
10			0.08				0.08
11			0.08				0.08
12			0.08				0.08
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Offline

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All daily turbidity readings ≤ 5 NTU? Yes		
Notes:	PRINTED NAME: Daniel Willyard	
	SIGNATURE: <i>Daniel Willyard</i>	DATE: Oct. 6, 2021
	PHONE #: (503) 436-8082	CERT #: D/T 1588

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

