

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Clatsop**
 Month/Year: **Dec-23**

System Name: **City of Cannon Beach** ID#: **41 -00164** WTP : **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
1			0.04				0.04	
2			0.05				0.05	
3			0.05				0.05	
4			0.05				0.05	
5			0.07				0.07	
6	Offline for the season							
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								

		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	YES	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	YES	YES	YES

Notes:	PRINTED NAME: Daniel Willyard	
	SIGNATURE: <i>Daniel Willyard</i>	DATE: 12/27/23
	PHONE #: (503) 436-8082	CERT #: 1588

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

System Name: City of Cannon Beach ID#: 41-00164

Month/Year: Dec-23

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.53	336	178.1	9.0	6.96	38.5	YES	430
2	0.54	312	168.5	9.0	6.96	38.6	YES	430
3	0.51	312	159.1	9.0	6.95	38.3	YES	420
4	0.54	301	162.5	9.0	6.95	38.5	YES	420
5	0.55	312	171.6	9.0	6.96	38.6	YES	410
6	Offline for the season							
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

~~dwp.dmce@oha.oregon.gov~~; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350
dwp.dmce@odhsoha.oregon.gov PAGE 2 of 2