

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Curry**
 Month/Year: **Apr-24**

Conventional or Direct Filtration

System Name:	City of Gold Beach		ID#: 4101059				WTP : TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	0.04	0.03	0.03	OFF	0.08	
2	OFF	OFF	0.03	0.03	0.04	OFF	0.08	
3	OFF	OFF	0.04	0.04	OFF	OFF	0.05	
4	OFF	0.04	0.04	0.05	OFF	OFF	0.08	
5	OFF	0.05	0.05	0.04	0.04	OFF	0.06	
6	OFF	OFF	0.04	0.06	0.04	OFF	0.08	
7	OFF	OFF	0.04	OFF	OFF	0.04	0.05	
8	0.04	OFF	OFF	0.06	0.04	OFF	0.08	
9	OFF	OFF	0.03	0.03	0.03	OFF	0.05	
10	OFF	OFF	OFF	OFF	0.04	0.04	0.06	
11	0.03	0.03	0.03	0.03	0.03	0.05	0.05	
12	OFF	OFF	0.03	0.03	0.03	0.03	0.04	
13	OFF	0.03	0.03	OFF	OFF	0.03	0.05	
14	OFF	OFF	OFF	0.03	0.03	0.02	0.03	
15	OFF	0.02	0.02	0.02	OFF	OFF	0.02	
16	0.02	0.02	OFF	0.02	0.02	OFF	0.05	
17	OFF	OFF	0.02	0.02	0.05	0.03	0.05	
18	OFF	OFF	OFF	OFF	0.02	0.02	0.02	
19	OFF	OFF	OFF	0.02	0.02	0.03	0.04	
20	OFF	OFF	OFF	0.02	0.02	0.02	0.03	
21	OFF	OFF	OFF	0.02	0.02	0.02	0.04	
22	OFF	OFF	OFF	0.02	0.02	0.02	0.05	
23	OFF	OFF	OFF	0.02	0.02	0.02	0.03	
24	OFF	OFF	OFF	0.04	0.05	0.04	0.05	
25	OFF	OFF	OFF	0.02	0.02	OFF	0.07	
26	OFF	OFF	OFF	0.02	0.03	OFF	0.05	
27	OFF	OFF	0.02	0.02	OFF	OFF	0.02	
28	OFF	0.02	0.02	OFF	0.04	0.02	0.05	
29	OFF	OFF	OFF	0.02	0.02	0.02	0.02	
30	OFF	OFF	OFF	0.04	0.02	0.02	0.04	
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All 4-hour turbidity readings ≤ 1 NTU? Yes		
All turbidity readings < IFE ² triggers Yes		

Notes:	PRINTED NAME: Will Newdall	
	SIGNATURE:	5/1/2024
	PHONE #: (541)247-7459	CERT #: FE0054

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Gold Beach	ID#: 4101059	Month/Year:	Nov-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	--------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.87	60	52.2	11.4	7.01	17.4	YES	700
2	0.85	60	51.0	15.2	7.05	13.5	YES	700
3	0.89	60	53.4	12.2	7.05	16.8	YES	700
4	0.8	60	48.0	14.5	7.00	13.8	YES	700
5	0.85	60	51.0	11.5	7.00	17.2	YES	700
6	0.89	60	53.4	13.6	7.00	14.8	YES	700
7	1.14	60	68.4	14.2	7.00	14.6	YES	700
8	0.83	60	49.8	11.3	6.97	17.2	YES	700
9	0.7	60	42.0	11.9	7.06	16.9	YES	700
10	0.77	60	46.2	11.5	7.01	17.1	YES	700
11	0.75	60	45.0	12.4	7.10	16.6	YES	700
12	0.94	60	56.4	14.0	7.10	15.0	YES	700
13	0.81	60	48.6	15.4	7.12	13.6	YES	700
14	0.83	60	49.8	14.1	7.05	14.5	YES	700
15	1.04	60	62.4	14.0	7.01	14.7	YES	700
16	0.93	60	55.8	12.5	6.98	15.8	YES	700
17	0.8	60	48.0	12.7	7.06	15.9	YES	700
18	0.84	60	50.4	15.8	7.04	12.9	YES	700
19	0.81	60	48.6	14.5	7.05	14.0	YES	700
20	0.83	60	49.8	15.4	7.06	13.3	YES	700
21	0.95	60	57.0	13.5	7.03	15.1	YES	700
22	0.78	60	46.8	14.4	6.96	13.6	YES	700
23	0.78	60	46.8	15.4	7.12	13.5	YES	700
24	0.82	60	49.2	13.1	7.05	15.4	YES	700
25	0.85	60	51.0	13.2	7.03	15.3	YES	700
26	0.7	60	42.0	14.4	7.04	13.9	YES	700
27	0.95	60	57.0	14.9	7.15	14.4	YES	700
28	0.93	60	55.8	15.6	7.10	13.5	YES	700
29	0.9	60	54.0	14.4	7.04	14.2	YES	700
30	0.88	60	52.8	14.7	7.15	14.5	YES	700
31							NO	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised September 2016

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350
 PAGE 2 of 2

Water Production Record for The City of Gold Beach

April 2024		Chlorine Residual			
Date	Gallons Pumped	Location 1	Residual	Location 2	Residual
1	285,000	City Hall	.65	HC or Wedd	
2	457,000	City Hall	.45	HC or Wedd	
3	346,000	City Hall	.70	HC or Wedd	
4	571,000	City Hall	.68	HC or Wedd	
5	301,000	City Hall		HC or Wedd	
6	440,000	City Hall		HC or Wedd	
7	414,000	City Hall		HC or Wedd	
8	344,000	City Hall	.48	HC or Wedd	
9	423,000	City Hall	.49	HC or Wedd	
10	357,000	City Hall	.59	HC or Wedd	
11	428,000	City Hall	.59	HC or Wedd	
12	364,000	City Hall		HC or Wedd	
13	485,500	City Hall		HC or Wedd	
14	248,000	City Hall		HC or Wedd	
15	663,000	City Hall	.54	HC or Wedd	
16	343,000	City Hall	.39	HC or Wedd	
17	250,000	City Hall	.44	HC or Wedd	
18	444,000	City Hall	.63	HC or Wedd	
19	313,000	City Hall		HC or Wedd	
20	498,000	City Hall		HC or Wedd	
21	380,000	City Hall		HC or Wedd	
22	588,000	City Hall	.66	HC or Wedd	
23	266,000	City Hall	.41	HC or Wedd	
24	407,000	City Hall	.70	HC or Wedd	
25	407,000	City Hall	.45	HC or Wedd	
26	130,000	City Hall		HC or Wedd	
27	708,000	City Hall		HC or Wedd	
28	500,000	City Hall		HC or Wedd	
29	427,000	City Hall	.75	HC or Wedd	
30	356,000	City Hall	.58	HC or Wedd	
31		City Hall		HC or Wedd	