

September 28, 2022



800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-673-0191 Fax: 971-673-0694 www.healthoregon.org/DWP

Steve Roper AKS Engineering & Forestry, LLC 12965 SW Herman Rd, Suite 100 Tualatin, OR 97062

Re: Faraday Hills No. 6 (PR#143-2022) City of Estacada (PWS ID#00279) Conditional Approval

Dear Steve:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for Faraday Hills No. 6 for the City of Estacada. On September 23, 2022, our office received a City Council findings and conditions document, a land use compatibility statement, sanitary plans, water plans and a transmittal submittal. On September 27, 2022, our office received a plan review fee of \$3,300.

The project includes connecting existing 8" C900 PVC water lines that are part of Faraday Hills Phase No. 1 to the main distribution line and installing the service connections to the properties along the length of that pipe.

The plans are approved with the following conditions:

• The design must allow for 20 psi to be maintained at all service meters.

Until we receive verification that the conditions have been met and final approval has been issued, Faraday Hills No. 6 is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #143-2022 and can be emailed to me at <u>keith.male@dhsoha.state.or.us</u>.

If you have any questions, please feel free to call me at (503) 939-1322.

Sincerely,

Mith Male

Keith Male, EIT Regional Engineer Drinking Water Services

cc: Julie Wray, DWS Carrie Gentry, PE, OHA/DWS Anne Boutwell, Project Coordinator, AKS Engineering & Forestry