



PUBLIC HEALTH DIVISION
Drinking Water Services
Tina Kotek, Governor

Oregon
Health
Authority

750 SE Emigrant Ave., Suite 150
Pendleton, OR 97801
(541) 276-8006
FAX (541) 276-4778
www.healthoregon.org/dwp

April 24, 2024

Marios Georgiou, PE
Conсор Engineers, LLC
345 Bobwhite Court, Suite 230
Boise, Idaho 83706

**Re: WesTech Treatment Plant Expansion, Plan Review #2023-60, City of Ontario,
PWS ID #4100587
Final Approval**

Dear Mr. Georgiou:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services confirming the project was completed in accordance with the approved plans. The project consisted of installing a WesTech Trident Model ½ TR-840A Custom train to the existing WesTech Claricell contact adsorption clarifier treatment plant, along with the necessary controls, piping, valves, appurtenances, and a new potassium permanganate diaphragm metering pump. This third 2-MGD capacity train will increase the total capacity of the plant to 6-MGD. Final approval is granted for the project.

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at william.h.goss@oha.oregon.gov .

Sincerely,

William Goss, PE
Regional Engineer

c: Julie Wray, OHA-DWS, Portland, OR
Joe Foote, PE, Conсор Engineers (pdf copy only)
Casey Mordhorst, Jacobs/City of Ontario (pdf copy only)
Dustin Mosher, Jacobs/City of Ontario (pdf copy only)
Paul Woods, PE, Jacobs/City of Ontario (pdf copy only)