



May 14, 2024

Eric Favreau, PE
Favreau Engineering
Via email: favreaueng@gmail.com

**Re: Blek's Mill Waterlines (PR#39-2024)
City of Veneta (PWS ID#00920)
Conditional Approval**

Dear Eric:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Blek's Mill Waterlines project in the City of Veneta water system. On February 16, 2024, our office received a set of plans. An unsigned LUCS was received on February 22, 2024. A plan review fee of \$3,300 was received on March 22, 2024.

The project includes installation of 6" and 8" ductile iron waterlines and associated appurtenances for the Blek's Mill subdivision project.

The plans are approved with the following conditions:

- The LUCS form that was submitted did not have the land use planner's signature on it. A LUCS form with the land use planners approval signature on it must be submitted in order for this conditional approval letter to be valid. Note that a DEQ form is acceptable, however, DWS has its own form available on our website.
- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- The breather tube on air-relief valves must be extended above ground surface and provided with a screened, downward facing elbow.
- Any sewer and water line crossings must conform to OAR 333-061-0050(9). Parallel separations must also conform to this rule. Note that any zone conflicts represented in figure in that rule other than zone 1 conflicts must be approved by OHA/DWS.
- Disinfection of the waterline must be completed according to AWWA C651. Results

from the coliform sampling must be provided to our office.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #39-2024 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Rebecca Templin, PE, OHA/DWS
Amy Bleekman, REHS, OHA/DWS
Kyle Schauer, Public Works Director, City of Veneta, kschauer@ci.veneta.or.us
Ryan Frome, ryanfrome@gmail.com