

Water System Name and PWS ID# ADAMS WATER DEPT, CITY OF, 41-00001 System Size Small System, 1-299 connections
Date Report was Received 03/08/21 10:55 AM ASR Contact Kelly Brady Email Address cityofadams1893@yahoo.com Contact Phone Number 541 379-0171
Residential Connection 149 High Hazard Connection 2 Other Connections 15 Total Connections 166
Enabling Authority Yes Did you revise your Enabling Authority? No
This section for LARGE Systems Only
Cross Connection Specialist Specialist Cert # WS Employee/Contracted Phone # Email Address Written Backflow Protection Program Written BFP program plan? List of high hazards Procedure Notify Water Users Type of Protection Corrective Action Current Records Public Education

<p>Do you have any RPs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of RPs tested</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 33</p> <p>Tested 33</p> <p>Passed 31</p> <p>Failed 2</p> <p>% of DCs tested 100%</p> <p>Comments The two failed assemblies were repaired, retested and passed</p>
<p>Do you have any PVBs? Yes</p> <p>How many 5</p> <p>Tested 5</p> <p>Passed 4</p> <p>Failed 1</p> <p>% of PVBs Tested 100%</p> <p>Comments The assembly that failed was repaired, retested and passed.</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system