

Water System Name and PWS ID#	AMITY, CITY OF, 41-00041
System Size	Large System, 300+ connections
Date Report was Received	03/08/21 1:12 PM
ASR Contact	Gary Mathis
Email Address	gmathis@ci.amity.or.us
Contact Phone Number	503-835-4181
Residential Connection	665
High Hazard Connection	2
Other Connections	55
Total Connections	722
Enabling Authority	Yes
Did you revise your Enabling Authority?	Yes, attach the revised copy below
This section for LARGE Systems Only	
Cross Connection Specialist	Gary Mathis
Specialist Cert #	6670
WS Employee/Contracted	Water System Employee, or
Phone #	503-835-4181
Email Address	gmathis@ci.amity.or.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
 How many 5
 Tested 4
 Passed 4
 Failed 0
 % of RPs tested 80%
 Comments

Do you have any DCs? Yes
 How many 116
 Tested 85
 Passed 85
 Failed 0
 % of DCs tested 73%
 Comments

Do you have any PVBs? No
 How many 0
 Tested
 Passed
 Failed
 % of PVBs Tested
 Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system