

2018 Annual Summary Report (ASR)

Row 97

Primary**Entered****Data Online****Water System Name**

FALCON COVE BEACH WD, 41-00045

ASR Contact

Charles A Dice

Email Address

cadice@hotmail.com

Contact Phone Number

503-440-3201

Residential Connections

92

High Hazard Connections

0

Other Connections

0

Enabling Authority

Yes

Revised Enabling Authority

No

CCCS Name**CCCS Information****CCCS Cert #****CCCS Phone****CCCS Email**

Current written
backflow
prevention
program plan?

BFPP - list of
high hazards

BFPP -
Procedure

BFPP Notify
Water User

BFPP - Type of
Protection

BFPP -
Corrective
Action

BFPP - Current
records

BFPP - Public
Education

Do you have
RP? No

RP - How Many

RP - Tested

RP - Passed

RP - Failed

% Tested #DIVIDE BY ZERO

RP - Comments

Do you have
any DC? Yes

DC - How Many 96

DC - Tested 96

DC - Passed 91

DC - Failed 5

DC - Comments

**Do you have
any PVBs?** No

**PVB - How
Many**

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify ☒

Column47
