

Water System Name and PWS ID#	FALCON COVE BEACH WD, 41-00045
System Size	Small System, 1-299 connections
Date Report was Received	05/09/21 8:43 AM
ASR Contact	Charles A Dice
Email Address	cadice@hotmail.com
Contact Phone Number	503-440-3201
Residential Connection	102.00
High Hazard Connection	0
Other Connections	0
Total Connections	102
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	n/a
Specialist Cert #	
WS Employee/Contracted	
Phone #	
Email Address	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards	
Procedure	
Notify Water Users	
Type of Protection	
Corrective Action	
Current Records	
Public Education	

<p>Do you have any RPs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of RPs tested</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 101</p> <p>Tested 101</p> <p>Passed 78</p> <p>Failed 23</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system