

<b>Water System Name and PWS ID#</b>	ASHLAND WATER DEPARTMENT, 41-00047
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	03/09/21 12:05 PM
<b>ASR Contact</b>	Larry Elliott
<b>Email Address</b>	larry.elliott@ashland.or.us
<b>Contact Phone Number</b>	541-552-2327
<b>Residential Connection</b>	7,997.00
<b>High Hazard Connection</b>	818
<b>Other Connections</b>	653
<b>Total Connections</b>	9468
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Larry Elliott
<b>Specialist Cert #</b>	#4920
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	541-552-2327
<b>Email Address</b>	larry.elliott@ashland.or.us
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	Yes

Do you have any RPs? Yes

How many 818

Tested 634

Passed 634

Failed 7

% of RPs tested 78%

Comments The seven assemblies that failed were on the initial test. After repair and re-test they passed.

Do you have any DCs? Yes

How many 2,877.00

Tested 2,044.00

Passed 2,042.00

Failed 2

% of DCs tested 71%

Comments The two assemblies that failed were on the initial test. After repair and re-test they passed.

Do you have any PVBs? Yes

How many 24

Tested 22

Passed 22

Failed 0

% of PVBs Tested 92%

Comments

I certify the information provided is true  
to the best of my knowledge. Providing  
false information may result in penalties  
to the individual and to the water system