

2018 Annual Summary Report (ASR)

Row 11

Primary

Entered

Water System Name ASTORIA, CITY OF, 41-00055

ASR Contact Eric Bufkin

Email Address ebufkin@astoria.or.us

Contact Phone Number 503-298-2503

Residential Connections 3850

High Hazard Connections 376

Other Connections 209

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Eric Bufkin

CCCS Information Water System Employee, or

CCCS Cert # 5769

CCCS Phone 503-298-2503

CCCS Email ebufkin@astoria.or.us

Current written backflow Yes

prevention program plan?	
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	No
Do you have RP?	Yes
RP - How Many	376
RP - Tested	369
RP - Passed	346
RP - Failed	23
% Tested	98%
RP - Comments	
Do you have any DC?	Yes
DC - How Many	367
DC - Tested	357
DC - Passed	347
DC - Failed	10
DC - Comments	

Do you have any PVBs?	Yes
------------------------------	-----

PVB - How Many	2
-----------------------	---

PVB - Tested	2
---------------------	---

PVB - Passed	2
---------------------	---

PVB - Failed	0
---------------------	---

PVB - Comments	
-----------------------	--

I certify	<input checked="" type="checkbox"/>
------------------	-------------------------------------

Column47	
-----------------	--
