

Water System Name and PWS ID#	ASTORIA, CITY OF, 41-00055
System Size	Large System, 300+ connections
Date Report was Received	03/03/21 1:46 PM
ASR Contact	Eric L Bufkin
Email Address	ebufkin@astoria.or.us
Contact Phone Number	503-468-8998
Residential Connection	3850
High Hazard Connection	380
Other Connections	210
Total Connections	4440
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Eric Bufkin
Specialist Cert #	5769
WS Employee/Contracted	Water System Employee, or
Phone #	503-468-8998
Email Address	ebufkin@astoria.or.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

Do you have any RPs? Yes
 How many 381
 Tested 362
 Passed 336
 Failed 26
 % of RPs tested 95%
 Comments

Do you have any DCs? Yes
 How many 370
 Tested 342
 Passed 332
 Failed 10
 % of DCs tested 92%
 Comments

Do you have any PVBs? Yes
 How many 2
 Tested 2
 Passed 2
 Failed 0
 % of PVBs Tested 100%
 Comments

I certify the information provided is true
 to the best of my knowledge. Providing ^{true}
 false information may result in penalties
 to the individual and to the water system