

Water System Name and PWS ID#	YOUNGS RIVER LEWIS & CLARK WD, 41-00062
System Size	Large System, 300+ connections
Date Report was Received	03/30/21 10:39 AM
ASR Contact	Carl Gifford
Email Address	carl@yrlcoffice.org
Contact Phone Number	503-325-4330
Residential Connection	919.00
High Hazard Connection	96
Other Connections	0
Total Connections	1015
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Carl Gifford
Specialist Cert #	6271
WS Employee/Contracted	Water System Employee, or
Phone #	503-325-4330
Email Address	carl@yrlcoffice.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 6</p> <p>Tested 6</p> <p>Passed 4</p> <p>Failed 2</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 90</p> <p>Tested 82</p> <p>Passed 78</p> <p>Failed 4</p> <p>% of DCs tested 91%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system