

Water System Name and PWS ID#	WICKIUP WATER DISTRICT, 41-00063
System Size	Large System, 300+ connections
Date Report was Received	10/25/21 12:04 PM
ASR Contact	Daniel Waterbury
Email Address	dan@wickiupwaterdistrict.com
Contact Phone Number	+1 (503) 791-5751
Residential Connection	656
High Hazard Connection	4
Other Connections	0
Total Connections	660
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	James C Jackson
Specialist Cert #	6200
WS Employee/Contracted	Contracted Service
Phone #	+1 (503) 741-1096
Email Address	kknappa@centurytel.net
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes

How many 6

Tested 3

Passed 1

Failed 2

% of RPs tested 50%

Comments The three that were not tested are attached to services that are off and locked.

Do you have any DCs? Yes

How many 13

Tested 10

Passed 9

Failed 1

% of DCs tested 77%

Comments

Do you have any PVBs? No

How many 0

Tested

Passed

Failed

% of PVBs Tested

Comments

I certify the information provided is true
to the best of my knowledge. Providing ^{true}
false information may result in penalties
to the individual and to the water system