

Water System Name and PWS ID#	ATHENA, CITY OF, 41-00064
System Size	Large System, 300+ connections
Date Report was Received	03/24/21 10:14 AM
ASR Contact	Kenneth Faircloth
Email Address	kenneth@cityofathena.com
Contact Phone Number	541-566-0228
Residential Connection	523.00
High Hazard Connection	4
Other Connections	3
Total Connections	530
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Kenneth Faircloth
Specialist Cert #	5456
WS Employee/Contracted	Water System Employee, or
Phone #	541-969-8489
Email Address	kenneth@cityofathena.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
How many 4
Tested 4
Passed 4
Failed 0
% of RPs tested 100%
Comments

Do you have any DCs? Yes
How many 29
Tested 29
Passed 29
Failed 0
% of DCs tested 100%
Comments

Do you have any PVBs? Yes
How many 5
Tested 5
Passed 5
Failed 0
% of PVBs Tested 100%
Comments

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system