

Water System Name and PWS ID#	AUMSVILLE, CITY OF, 41-00065
System Size	Large System, 300+ connections
Date Report was Received	03/17/21 10:26 AM
ASR Contact	Steven Oslie
Email Address	soslie@aumsville.us
Contact Phone Number	503-749-1185
Residential Connection	1,200.00
High Hazard Connection	12
Other Connections	0
Total Connections	1212
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Steve Oslie
Specialist Cert #	2647
WS Employee/Contracted	Water System Employee, or
Phone #	503-749-1185
Email Address	soslie@aumsville.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes

How many 27

Tested 26

Passed 24

Failed 2

% of RPs tested 96%

Comments The 2 RP's that failed were repaired and passed. 1 RP is off and locked until the customer wants the water turned back on, at which time it will be tested.

Do you have any DCs? Yes

How many 382

Tested 368

Passed 352

Failed 12

% of DCs tested 96%

Comments The 12 DCVA that failed the first test has all been repaired. Shut off notices have been sent to past-due customers

4 detector check valve assemblies are included with the DCVA total

Do you have any PVBs? No

How many 0

Tested

Passed

Failed

% of PVBs Tested

Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system