KELLER Molly A

From:Molly Keller via Smartsheet <user@smartsheet.com>Sent:Friday, February 21, 2020 12:11 PMTo:Molly KellerSubject:BAY CITY WATER SYSTEM, 41-00079

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.

BAY CITY WATER SYSTEM, 41-00079		
2019 Annual Summary Report (ASR)		
Row 38		
Primary		
Entered		
Data Online		
Water System Name	BAY CITY WATER SYSTEM, 41-00079	
ASR Contact	bettis bettis	
Email Address	bbettis@ci.bay-city.or.us	
Contact Phone Number	503-377-4121	
Residential Connections	768	
High Hazard Connections	8	
Other Connections	54	
Enabling Authority	Yes	

Νο
bettis bettis
Water System Employee, or
5425
503-377-4121
bbettis@ci.bay-city.or.us
Yes
Yes
Νο
Yes
Yes
Yes

BFPP - Current records - Large system only	Yes
BFPP - Public Education - Large system only	Νο
Do you have RP?	Yes
RP - How Many	19
RP - Tested	19
RP - Passed	18
RP - Failed	1
% Tested	100%
RP - Comments	repair was made on the RP that failed initial test on the same day. retested and passed
Do you have any DC?	Yes
DC - How Many	13
DC - Tested	13
DC - Passed	10
DC - Failed	3
DC - Comments	repairs were made to the three that failed initial test retested and passed
Do you have any PVBs?	Yes
PVB - How Many	1
PVB - Tested	1
PVB - Passed	1
PVB - Failed	0
PVB - Comments	

I certify	
View in Smartsheet	

Sent using <u>Smartsheet</u> - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast. Sent by molly.a.keller@state.or.us © 2020 Smartsheet Inc. | <u>Contact</u> | <u>Privacy Policy</u> | <u>User Agreement</u> | <u>Report Abuse/Spam</u>