

| Water System Name and PWS ID# BAY CITY WATER SYSTEM, 41-00079 |
|---|
| System Size Large System, 300+ connections |
| Date Report was Received 02/12/21 11:32 AM |
| ASR Contact brian bettis |
| Email Address bbettis@ci.bay-city.or.us |
| Contact Phone Number ⁵⁰³⁻³⁷⁷⁻⁴¹²¹ |
| Residential Connection ₈₀₄ |
| High Hazard Connection ₈ |
| Other Connections 54 |
| Total Connections 866 |
| Enabling Authority Yes |
| Did you revise your Enabling Authority?No |
| This section for LARGE Systems Only |
| Cross Connection Specialist brian bettis |
| Specialist Cert # ⁵⁴²⁵ |
| WS Employee/Contracted Water System Employee, or |
| Phone # ⁵⁰³⁻³⁷⁷⁻⁴¹²¹ |
| Email Address bbettis@ci.bay-city.or.us |
| Written Backflow Protection Program |
| Written BFP program plan? Yes |
| List of high hazards Yes |
| Procedure ^{No} |
| Notify Water Users Yes |
| Type of Protection Yes |
| Corrective Action ^{Yes} |
| Current Records Yes |
| Public Education ^{No} |
| |



| $D_{2} = 1 = 1 = 1 = 1 = 2 = 2 = 2 = 2 = 2 = 2$ | |
|---|--|
| Do you have any RPs? Yes | |
| How many ²² | |
| Tested ¹⁸ | |
| Passed ¹⁸ | |
| Failed ⁴ | |
| % of RPs tested ^{82%} | |
| | |
| Comments 3 assemblies that failed the company did not test in time the other 1 assembly was replaced but not retested in time | |
| Do you have any DCs? ^{Yes} | |
| How many ¹⁹ | |
| Tested ¹⁵ | |
| Passed ¹⁵ | |
| Failed ⁴ | |
| % of DCs tested ^{79%} | |
| | |
| Comments the 4 assemblies the company did not test in time | |
| Do you have any PVBs?Yes | |
| How many ¹ | |
| Tested ¹ | |
| Passed ¹ | |
| Failed ⁰ | |
| | |
| % of PVBs Tested 100% | |
| Comments | |

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system