

| | |
|------------------------------------------------|-----------------------------------------|
| Water System Name and PWS ID# | BLACK BUTTE RANCH CORPORATION, 41-00086 |
| System Size | Large System, 300+ connections |
| Date Report was Received | 03/18/21 1:27 PM |
| ASR Contact | Mark Miskowiec |
| Email Address | mmiskowiec@bbranch.org |
| Contact Phone Number | 541-595-1280 |
| Residential Connection | 1,252.00 |
| High Hazard Connection | 2 |
| Other Connections | 19 |
| Total Connections | 1273 |
| Enabling Authority | Yes |
| Did you revise your Enabling Authority? | Yes, attach the revised copy below |
| This section for LARGE Systems Only | |
| Cross Connection Specialist | Mark Miskowiec |
| Specialist Cert # | 4936 |
| WS Employee/Contracted | Water System Employee, or |
| Phone # | 541-595-1280 |
| Email Address | mmiskowiec@bbranch.org |
| Written Backflow Protection Program | |
| Written BFP program plan? | Yes |
| List of high hazards | Yes |
| Procedure | Yes |
| Notify Water Users | Yes |
| Type of Protection | Yes |
| Corrective Action | Yes |
| Current Records | Yes |
| Public Education | Yes |

| |
|------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>Do you have any RPs? Yes</p> <p>How many 37</p> <p>Tested 37</p> <p>Passed 36</p> <p>Failed 1</p> <p>% of RPs tested 100%</p> <p>Comments</p> |
| <p>Do you have any DCs? Yes</p> <p>How many 494</p> <p>Tested 494</p> <p>Passed 479</p> <p>Failed 25</p> <p>% of DCs tested 100%</p> <p>Comments</p> |
| <p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p> |

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system