

# 2018 Annual Summary Report (ASR)

Row 17

---

## Primary

---

Entered

Data Online

Water System Name AVION WC - GREATER AVION, 41-00091

ASR Contact Mary Safranek

Email Address mary@avionwater.com

Contact Phone Number 541-948-2291

Residential Connections 12055

High Hazard Connections 54

Other Connections 249

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Mary Safranek

CCCS Information Water System Employee, or

CCCS Cert # 1756

CCCS Phone 541-948-2291

CCCS Email mary@avionwater.com

---

<b>Current written backflow prevention program plan?</b>	Yes
<b>BFPP - list of high hazards</b>	Yes
<b>BFPP - Procedure</b>	Yes
<b>BFPP Notify Water User</b>	Yes
<b>BFPP - Type of Protection</b>	Yes
<b>BFPP - Corrective Action</b>	Yes
<b>BFPP - Current records</b>	Yes
<b>BFPP - Public Education</b>	Yes
<b>Do you have RP?</b>	Yes
<b>RP - How Many</b>	61
<b>RP - Tested</b>	61
<b>RP - Passed</b>	61
<b>RP - Failed</b>	6
<b>% Tested</b>	100%
<b>RP - Comments</b>	
<b>Do you have any DC?</b>	Yes
<b>DC - How Many</b>	10813
<b>DC - Tested</b>	10713
<b>DC - Passed</b>	10713
<b>DC - Failed</b>	386

---

**DC - Comments**

---

**Do you have any PVBs?**      No

---

**PVB - How Many**

---

**PVB - Tested**

---

**PVB - Passed**

---

**PVB - Failed**

---

**PVB - Comments**

---

**I certify**     

---

**Column47**

---