

Water System Name and PWS ID#	AVION WC - GREATER AVION, 41-00091
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 1:42 PM
ASR Contact	KARMAN BURNETT
Email Address	Karman@avionwater.com
Contact Phone Number	541-325-2958
Residential Connection	12,098.00
High Hazard Connection	55
Other Connections	248
Total Connections	12401
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Karman Burnett
Specialist Cert #	406274
WS Employee/Contracted	Water System Employee, or
Phone #	541-325-2958
Email Address	Karman@avionwater.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 59</p> <p>Tested 59</p> <p>Passed 59</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 7496</p> <p>Tested 7496</p> <p>Passed 7496</p> <p>Failed 263</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system