

<b>Water System Name and PWS ID#</b>	BEND WATER DEPARTMENT, 41-00100
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	02/18/21 9:16 AM
<b>ASR Contact</b>	Donald Buhmann
<b>Email Address</b>	dbuhmann@bendoregon.gov
<b>Contact Phone Number</b>	541-419-0209
<b>Residential Connection</b>	22053
<b>High Hazard Connection</b>	175
<b>Other Connections</b>	4563
<b>Total Connections</b>	26791
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Donald Buhmann
<b>Specialist Cert #</b>	5950
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	541-419-0209
<b>Email Address</b>	dbuhmann@bendoregon.gov
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	Yes

<p>Do you have any RPs? Yes</p> <p>How many 1290</p> <p>Tested 1194</p> <p>Passed 1154</p> <p>Failed 40</p> <p>% of RPs tested 93%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 35769</p> <p>Tested 30288</p> <p>Passed 30019</p> <p>Failed 269</p> <p>% of DCs tested 85%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 28</p> <p>Tested 26</p> <p>Passed 26</p> <p>Failed 0</p> <p>% of PVBs Tested 93%</p> <p>Comments</p>

I certify the information provided is true  
to the best of my knowledge. Providing  
false information may result in penalties  
to the individual and to the water system