

2018 Annual Summary Report (ASR)

Row 255

Primary

Entered
Data Online
Water System Name PONDEROSA PINES WATER COMPANY, 41-00106

ASR Contact Ryan Price

Email Address gunzprice@msn.com

Contact Phone Number 619-977-6534

Residential Connections 451

High Hazard Connections 0

Other Connections 3

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Ryan Price

CCCS Information Water System Employee, or

CCCS Cert # Pending State Certification

CCCS Phone 619-977-6534

CCCS Email gunzprice@msn.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	No
RP - How Many	
RP - Tested	
RP - Passed	
RP - Failed	
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	454
DC - Tested	454
DC - Passed	454
DC - Failed	14 failed initially. They were repaired/serviced. All passed retesting.
DC - Comments	
Do you have any PVBs?	No
PVB - How Many	

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
