

Water System Name and PWS ID#	ROATS WATER SYSTEM, 41-00113
System Size	Large System, 300+ connections
Date Report was Received	02/26/21 12:02 PM
ASR Contact	Michelle Berg
Email Address	michelle@roatswater.com
Contact Phone Number	541-382-3029
Residential Connection	2156
High Hazard Connection	79
Other Connections	117
Total Connections	2352
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Michelle Berg
Specialist Cert #	977215
WS Employee/Contracted	Water System Employee, or
Phone #	541-382-3029
Email Address	michelle@roatswater.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 48</p> <p>Tested 48</p> <p>Passed 45</p> <p>Failed 3</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 1906</p> <p>Tested 1906</p> <p>Passed 1863</p> <p>Failed 43</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system