

<b>Water System Name and PWS ID#</b>	BOARDMAN, CITY OF, 41-00130
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	03/23/21 9:00 AM
<b>ASR Contact</b>	Luis
<b>Email Address</b>	camposl@cityofboardman.com
<b>Contact Phone Number</b>	541-701-8880
<b>Residential Connection</b>	914.00
<b>High Hazard Connection</b>	31
<b>Other Connections</b>	AVB 7
<b>Total Connections</b>	945
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	Yes, attach the revised copy below
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Luis Campos
<b>Specialist Cert #</b>	900039
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	541-701-8880
<b>Email Address</b>	camposl@cityofboardman.com
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	Yes

Do you have any RPs? Yes  
 How many 31  
 Tested 31  
 Passed 31  
 Failed 0  
 % of RPs tested 100%  
 Comments

Do you have any DCs? Yes  
 How many 93  
 Tested 91  
 Passed 89  
 Failed 2  
 % of DCs tested 98%  
 Comments

Do you have any PVBs? Yes  
 How many 7  
 Tested 7  
 Passed 7  
 Failed 0  
 % of PVBs Tested 100%  
 Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system