

2018 Annual Summary Report (ASR)

Row 45

Primary

Entered

Data Online

Water System Name BROOKINGS, CITY OF, 41-00149

ASR Contact Tim Brush

Email Address tbrush@brookings.or.us

Contact Phone Number 541-469-1173

Residential Connections 3150

High Hazard Connections 82

Other Connections 260

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Tim Brush

CCCS Information Water System Employee, or

CCCS Cert # 6348

CCCS Phone 541-469-1173

CCCS Email tbrush@brookings.or.us

Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	No
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	No
Do you have RP?	Yes
RP - How Many	82
RP - Tested	79
RP - Passed	77
RP - Failed	2
% Tested	
RP - Comments	THE TWO RPBA THAT FAILED WERE RE-TESTED AND PASSED.
Do you have any DC?	Yes
DC - How Many	211
DC - Tested	206
DC - Passed	197
DC - Failed	9

DC - Comments DCs THAT FAILED WERE RE-TESTED OR REPLACED.

Do you have any PVBs? Yes

PVB - How Many 2

PVB - Tested 1

PVB - Passed 1

PVB - Failed 1

PVB - Comments BOTH WILL BE REQUIRED TO BE TESTED IN 2019.

I certify

Column47
