

Water System Name and PWS ID# BROOKINGS, CITY OF, 41-00149
System Size Large System, 300+ connections
Date Report was Received ^{03/30/21 4:31 PM}
ASR Contact ^{Tim Brush}
Email Address tbrush@brookings.or.us
Contact Phone Number ⁵⁴¹⁻⁴⁶⁹⁻¹¹⁷³
Residential Connection 3,225.00
High Hazard Connection ₈₆
Other Connections 248
Total Connections 3559
Enabling Authority Yes
Did you revise your Enabling Authority?No
This section for LARGE Systems Only
Cross Connection Specialist ^{Tim Brush}
Specialist Cert $\#^{6348}$
WS Employee/Contracted Water System Employee, or
Phone # ⁵⁴¹⁻⁴⁶⁹⁻¹¹⁷³
Email Address tbrush@brookings.or.us
Written Backflow Protection Program
Written BFP program plan? Yes
List of high hazards ^{No}
Procedure Yes
Notify Water Users Yes
Type of Protection Yes
Corrective Action ^{Yes}
Current Records Yes
Public Education ^{No}



Do you have any RPs? Yes
How many ⁸⁶
Tested ⁸⁶
Passed ⁸⁴
Failed ²
% of RPs tested ^{100%}
Comments
Do you have any DCs? ^{Yes}
How many ²³¹
Tested ²²⁶
Passed ²²³
Failed ³
% of DCs tested ^{98%}
Comments
Do you have any PVBs?Yes
How many ²
Tested ¹
Passed ¹
Failed ¹
% of PVBs Tested 50%
Comments We have a total of 2 PVB in our system, the 2nd one did not get tested but will be following up to make sure it is tested in 2021. Tim Brush
Tim Brush

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system