

Water System Name and PWS ID#	BURNS WATER DEPARTMENT, 41-00153
System Size	Large System, 300+ connections
Date Report was Received	03/11/21 9:10 AM
ASR Contact	Michael Berry
Email Address	Mberry@ci.burns.or.us
Contact Phone Number	541-589-1367
Residential Connection	1,300.00
High Hazard Connection	47
Other Connections	108
Total Connections	1455
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Roy Crafts
Specialist Cert #	5701
WS Employee/Contracted	Water System Employee, or
Phone #	541-589-1458
Email Address	rcrafts
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 31</p> <p>Tested 29</p> <p>Passed 26</p> <p>Failed 3</p> <p>% of RPs tested 94%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 73</p> <p>Tested 65</p> <p>Passed 65</p> <p>Failed 0</p> <p>% of DCs tested 89%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 1</p> <p>Tested 1</p> <p>Passed 1</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system