

2018 Annual Summary Report (ASR)

Row 48

Primary

Entered ☒**Data Online** ☐

Water System Name BUTTE FALLS, TOWN OF, 41-00154

ASR Contact Chris Bray

Email Address bfwntp@gmail.com

Contact Phone Number 541-816-5184

Residential Connections 269

High Hazard Connections 5

Other Connections 9

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name

CCCS Information

CCCS Cert #

CCCS Phone

CCCS Email

**Current written
backflow
prevention
program plan?**

**BFPP - list of
high hazards**

**BFPP -
Procedure**

**BFPP Notify
Water User**

**BFPP - Type of
Protection**

**BFPP -
Corrective
Action**

**BFPP - Current
records**

**BFPP - Public
Education**

**Do you have
RP?** Yes

RP - How Many 14

RP - Tested 14

RP - Passed 14

RP - Failed 0

% Tested 100%

RP - Comments

**Do you have
any DC?** No

DC - How Many

DC - Tested

DC - Passed

DC - Failed

DC - Comments

**Do you have
any PVBs?** No

**PVB - How
Many**

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify ☒

Column47
