

Water System Name and PWS ID#	PETES MOUNTAIN WATER CO, 41-00161
System Size	Small System, 1-299 connections
Date Report was Received	03/29/21 10:37 AM
ASR Contact	Phillip Merrill
Email Address	info@merrillwater.com
Contact Phone Number	503-734-7400
Residential Connection	86.00
High Hazard Connection	0
Other Connections	0
Total Connections	86
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	
Specialist Cert #	
WS Employee/Contracted	
Phone #	
Email Address	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards	
Procedure	
Notify Water Users	
Type of Protection	
Corrective Action	
Current Records	
Public Education	

<p>Do you have any RPs? Yes</p> <p>How many 7</p> <p>Tested 4</p> <p>Passed 4</p> <p>Failed 0</p> <p>% of RPs tested 57%</p> <p>Comments Testers were unable to get access to customers property.</p>
<p>Do you have any DCs? Yes</p> <p>How many 111</p> <p>Tested 49</p> <p>Passed 49</p> <p>Failed 0</p> <p>% of DCs tested 44%</p> <p>Comments Many of the Double checks are after the double check at the meter and are listed in in system but not required to be tested.</p>
<p>Do you have any PVBs? Yes</p> <p>How many 1</p> <p>Tested 1</p> <p>Passed 1</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system