

Water System Name and PWS ID#	CASCADE LOCKS, CITY OF, 41-00172
System Size	Large System, 300+ connections
Date Report was Received	10/24/21 6:16 PM
ASR Contact	Philip Agnor
Email Address	philip@midcolumbiabackflow.com
Contact Phone Number	+1 (541) 490-4025
Residential Connection	300
High Hazard Connection	7
Other Connections	0
Total Connections	307
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Philip Agnor
Specialist Cert #	743411
WS Employee/Contracted	Contracted Service
Phone #	+1 (541) 490-4025
Email Address	philip@midcolumbiabackflow.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

<p>Do you have any RPs? Yes</p> <p>How many 9</p> <p>Tested 9</p> <p>Passed 9</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 39</p> <p>Tested 26</p> <p>Passed 26</p> <p>Failed 0</p> <p>% of DCs tested 67%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system