

Water System Name and PWS ID#	CENTRAL POINT, CITY OF, 41-00178
System Size	Large System, 300+ connections
Date Report was Received	03/15/21 3:17 PM
ASR Contact	Ronald Davis
Email Address	ronnie.davis@centralpointoregon.gov
Contact Phone Number	541-841-6623
Residential Connection	6,624.00
High Hazard Connection	157
Other Connections	79
Total Connections	6860
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Ronald Davis
Specialist Cert #	924759
WS Employee/Contracted	Water System Employee, or
Phone #	541-841-6623
Email Address	ronnie.davis@centralpointoregon.gov
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes

How many 157

Tested 78

Passed 78

Failed 0

% of RPs tested 50%

Comments We recently conducted residential site surveys and added a large amount of assemblies that were not in our system before.

Do you have any DCs? Yes

How many 3051

Tested 2460

Passed 2460

Failed 0

% of DCs tested 81%

Comments

Do you have any PVBs? Yes

How many 7

Tested 5

Passed 5

Failed 0

% of PVBs Tested 71%

Comments

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system