

Water System Name and PWS ID#	COOS BAY NORTH BEND WTR BRD, 41-00205
System Size	Large System, 300+ connections
Date Report was Received	03/15/21 7:52 AM
ASR Contact	VINCE STONESIFER
Email Address	vince_stonesifer@cbnbh2o.com
Contact Phone Number	541-267-3128 EXT 219
Residential Connection	11,259.00
High Hazard Connection	870
Other Connections	1164
Total Connections	13293
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	VINCE STONESIFER
Specialist Cert #	4789
WS Employee/Contracted	Water System Employee, or
Phone #	541-267-3128 EXT 219
Email Address	vince_stonesifer@cbnbh2o.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

Do you have any RPs? Yes

How many 1236

Tested 1171

Passed 1037

Failed 74

% of RPs tested 95%

Comments SOME CLOSED ACCOUNTS AND SOME WAITING FOR REPAIRS

Do you have any DCs? Yes

How many 287

Tested 262

Passed 247

Failed 9

% of DCs tested 91%

Comments

Do you have any PVBs? Yes

How many 1

Tested 1

Passed 1

Failed 0

% of PVBs Tested 100%

Comments

I certify the information provided is true
to the best of my knowledge. Providing ^{true}
false information may result in penalties
to the individual and to the water system