

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Tuesday, January 28, 2020 3:52 PM
To: Molly Keller
Subject: CORVALLIS, CITY OF, 41-00225

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



CORVALLIS, CITY OF, 41-00225

2019 Annual Summary Report (ASR)

Row 61

Primary

Entered

Data Online

Water System Name CORVALLIS, CITY OF, 41-00225

ASR Contact Carl Schaumburg

Email Address carl.schaumburg@corvallisoregon.gov

Contact Phone Number 541-754-1768

Residential Connections 17,124.00

High Hazard Connections 1049

Other Connections 5138

Enabling Authority Yes

Revised Enabling Authority	No
CCCS Name	Carl Schaumburg
CCCS Information	Water System Employee, or
CCCS Cert #	009193
CCCS Phone	541-754-1768
CCCS Email	carl.schaumburg@corvallisoregon.gov
Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	1049
RP - Tested	884
RP - Passed	864
RP - Failed	20
% Tested	

**RP -
Comments**

**Do you have
any DC?** Yes

DC - How Many 4531

DC - Tested 4398

DC - Passed 4360

DC - Failed 38

**DC -
Comments**

**Do you have
any PVBs?** Yes

**PVB - How
Many** 137

PVB - Tested 121

PVB - Passed 119

PVB - Failed 2

**PVB -
Comments**

I certify

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)