

2018 Annual Summary Report (ASR)

Row 270

Primary

Entered

Data Online

Water System Name RIDGEWOOD DIST IMPROV CO, 41-00229

ASR Contact Roger Kolodziej

Email Address rogerk@proaxis.com

Contact Phone Number 541-752-7614

Residential Connections 41

High Hazard Connections 0

Other Connections 0

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name

CCCS Information

CCCS Cert #

CCCS Phone

CCCS Email

Current written backflow prevention program plan?

BFPP - list of high hazards

BFPP - Procedure

BFPP Notify Water User

BFPP - Type of Protection

BFPP - Corrective Action

BFPP - Current records

BFPP - Public Education

Do you have RP? No

RP - How Many

RP - Tested

RP - Passed

RP - Failed

% Tested #DIVIDE BY ZERO

RP - Comments

Do you have any DC? Yes

DC - How Many 22

DC - Tested 10

DC - Passed 10

DC - Failed 0

DC - Comments Per approval from the Benton County Sanitarium, RDIC tests 1/2 of the backflow devices every other year. Ensuring 100% testing every 2 years.

Do you have any PVBs? No

PVB - How

Many

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
