

2018 Annual Summary Report (ASR)

Row 351

Primary

Entered

Data Online

Water System Name WESLINN WATER COMPANY, 41-00230

ASR Contact Jody Anthony

Email Address joeanthony.nwos@gmail.com

Contact Phone Number 541-990-9835

Residential Connections 60

High Hazard Connections 0

Other Connections 0

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name

CCCS Information

CCCS Cert #

CCCS Phone

CCCS Email

Current written backflow prevention program plan?

**BFPP - list of
high hazards**

**BFPP -
Procedure**

**BFPP Notify
Water User**

**BFPP - Type of
Protection**

**BFPP -
Corrective
Action**

**BFPP - Current
records**

**BFPP - Public
Education**

**Do you have
RP?** Yes

RP - How Many 1

RP - Tested 1

RP - Passed 1

RP - Failed 0

% Tested 100%

RP - Comments

**Do you have
any DC?** Yes

DC - How Many 24

DC - Tested 24

DC - Passed 21

DC - Failed 3

DC - Comments

**Do you have
any PVBs?** Yes

**PVB - How
Many** 5

PVB - Tested 5

PVB - Passed 4

PVB - Failed 1

**PVB -
Comments**

I certify

Column47
