

Water System Name and PWS ID#	WESLINN WATER COMPANY, 41-00230
System Size	Small System, 1-299 connections
Date Report was Received	02/26/21 9:47 AM
ASR Contact	Jody L Anthony
Email Address	joeanthony.nwos@gmail.com
Contact Phone Number	541-990-9835
Residential Connection	60
High Hazard Connection	0
Other Connections	0
Total Connections	60
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	na
Specialist Cert #	
WS Employee/Contracted	
Phone #	
Email Address	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards	
Procedure	
Notify Water Users	
Type of Protection	
Corrective Action	
Current Records	
Public Education	

<p>Do you have any RPs? Yes</p> <p>How many 1</p> <p>Tested 1</p> <p>Passed 1</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 24</p> <p>Tested 24</p> <p>Passed 24</p> <p>Failed 0</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 5</p> <p>Tested 5</p> <p>Passed 5</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system